

**TOWN OF FORT MACLEOD**  
**BY-LAW NO. 1805**

**BEING A BYLAW OF THE TOWN OF FORT MACLEOD**  
**RESPECTING THE MANAGEMENT AND REGULATION OF**  
**SEWERS WITHIN THE TOWN**

WHEREAS the Municipal Government Act, Chapter M-26, RSA 2000, as amended, provides for a Municipal Council passing bylaws or resolutions to maintain, manage or conduct any public utility; and

WHEREAS the Town of Fort Macleod has constructed and maintains and operates a sewerage system; and

WHEREAS the Town of Fort Macleod Wastewater Treatment Plants discharges are subject to Provincial Environment license requirements;

NOW THEREFORE the Municipal Council of the Town of Fort Macleod duly assembled, enacts as follows:

**PART I**  
**DEFINITIONS**

The definitions contained in the Safety Codes Act, R.S.A. 1991, Chapter S-0.5 as amended and regulations adopted thereunder shall be used in construing the sections of this Bylaw in addition to the definitions which follow:

- 101 BIOCHEMICAL OXYGEN DEMAND (BOD) - is a measure of the oxygen equivalent of the organic matter content of a sample that is susceptible to oxidation by process bacteria.
- 102 BODY OF WATER means any creek, stream, river, pond, lake, waterway, watercourse, canal or other flowing or standing water.
- 103 BUILDING DRAIN - means the lowest horizontal piping that conducts Clearwater waste, wastewater, storm water or water to a building sewer.
- 104 BUILDING SEWER - means that part of a drainage system outside a building commencing at the outer face of the wall of the building and connecting the building drain to the main sewer and terminating at the property line or place of disposal of wastewater.
- 105 CATCH BASIN - is an interceptor or area drain installed to prevent sand, grit, and other materials from passing into a drainage system.
- 106 CHEMICAL OXYGEN DEMAND (C.O.D.) - is a measure of the oxygen equivalent of the organic matter content of a sample that is susceptible to oxidation by a strong chemical oxidant.
- 107 CLEARWATER WASTE - means water that does not contain wastewater or storm water and to which no substance has been added.
- 108 COMBINED SEWER means a sewer that is intended to conduct wastewater and storm water.
- 109 COMPOSITE SAMPLE - is a sample composed of a number of grab samples which have been collected over a specified period of time, usually 24 hours or the industry's operating day, and combined in proportion to the volume of wastewater discharge they represent.
- 110 CONVENTIONAL POLLUTANTS - may include non-filterable residue (suspended solids), grease and oils, phosphorus, fecal and total coliform bacteria and substances the exert biochemical oxygen demand, chemical oxygen demand or that affect pH.
- 111 FIXTURE - means a receptacle, appliance, apparatus or other device that discharges wastewater or Clearwater waste and includes a floor drain.
- 112 FLOOR DRAIN - means a fixture used to receive water from a floor of a building.
- 113 GARBAGE - includes the solid waste from the preparation, cooking, and dispensing of food, and from the handling, storage, and sale of produce.

2  
**TOWN OF FORT MACLEOD**  
**BY-LAW NO. 1805**

**PART I**  
**DEFINITIONS (cont'd.)**

- 114 GRAB SAMPLE - is a sample collected over a short period of time by taking and combining one or more samples of wastewater flow.
- 115 HEALTH OFFICER - shall mean the Medical Officer of Health for the Town of Fort Macleod or the duly authorized representative of the Health Officer.
- 116 HYDROCARBONS OF PETROLEUM ORIGIN - are those materials which absorb onto Silica gel as described in the "hydrocarbon" method.
- 117 INSPECTOR - is a person authorized by the Manager to make inspections and/or to take samples where required and to otherwise enforce this Bylaw.
- 118 INDUSTRIAL WASTEWATER - is wastewater from industrial processes.
- 119 MANAGER shall mean the Town of Fort Macleod Town Manager or his designate.
- 120 MERCAPTANS (THIOLS) - means the sulphur analogs of alcohol and phenols with the general chemical formula RSH where R is the organic portion of the molecule.
- 121 NATURAL OUTLET - is any outlet from a natural water course into another water course, pond, ditch or lake, or other body of surface or groundwater.
- 122 NONFILTERABLE RESIDUE & SUSPENDED SOLIDS - means the solid matter suspended in water or wastewater.
- 123 OIL AND GREASE - means an organic substance recoverable by procedures set forth in "Standard Methods" and includes but is not limited to hydrocarbons, esters, fats, oils, waxes and high molecular carboxylic acids.
- 124 OWNER - includes the registered owner of a property and the person in charge of the premises.
- 125 PERSON - shall mean any individual, firm, company, association, society, corporation or group.
- 126 PH - means the measure of the intensity of the acid or alkaline conditions of a solution determined by the hydrogen ion activity of the solution in accordance with procedures set forth in "Standard Methods."
- 127 PHENOLIC COMPOUNDS - means hydroxyl derivatives of benzene and its condensed nuclei. Concentrations of phenolic compounds shall be determined using either the 4-amino antipyrine method or the gas liquid chromatographic procedure given in Standard Methods.
- 128 PHOSPHORUS (Total) - includes all orthophosphates and condensed phosphates, both dissolved and particulate, organic, and inorganic released from combination with organic matter by a digestion process as rigorous as or less rigorous than, the Sulfuric acid - nitric acid digestion.
- 129 POLLUTANT - means a chemical or material that is added to the water that causes an adverse deviation from the mean geochemical composition of the water.
- Pollutants shall be classified as conventional, non-conventional and priority. Non-conventional pollutants are those not classified as conventional or priority.
- 130 POLLUTED COOLING WATER - cooling waters to which chemicals have been added for the purpose of inhibiting bacterial growth in the cooling water system.
- 131 PRIORITY POLLUTANTS - includes chemicals and metals that have a toxic effect on the biological activity of the wastewater treatment processes and/or the receiving stream. These may include phenolic compounds, pesticides, chlorinated hydrocarbons, antimony, arsenic, barium, boron, chromium, copper, cadmium, lead, mercury, nickel, selenium, silver, and zinc.

3  
**TOWN OF FORT MACLEOD**  
**BY-LAW NO. 1805**

**PART I**  
**DEFINITIONS (cont'd.)**

- 132 RECEIVING WATERS - means the Oldman River or any other watercourse receiving or ultimately receiving the discharge of wastewater, Clearwater waste or storm water,
- 133 SANITARY SEWER - means a sewer which carries wastewater and to which storm, surface and ground waters are not intentionally admitted.
- 134 SEWAGE - means any liquid waste from a fixture
- 135 SEWER - is a pipe or conduit for carrying storm water, Clearwater waste, water or wastewater.
- 136 SEWER SERVICE - means that part of a sewer line from the building to the main line or point of wastewater disposal.
- 137 SEWERAGE SYSTEM - means a sewer or system of sewers or any plants, structures, equipment, pipes, apparatus or other things for or incidental to the collection, treatment or disposal of wastewater.
- 138 SEWERAGE PROJECT- means all construction for collection transportation, pumping, treatment and final disposal of wastewater or any part thereof.
- 139 STANDARD METHODS - means the current edition of "Standard Methods for the Examination of Water and Wastewater," American Public Health Association, Washington, D.C.
- 140 STORM SEWER - means a sewer that is installed to convey storm water and surface drainage.
- 141 SURFACE WATER - means water in a watercourse.
- 142 TOWN means the Town of Fort Macleod or the area contained within its municipal boundaries as the context requires.
- 143 TRUE COLOUR UNITS - means the measure of the colour of the water from which turbidity has been removed.
- 144 UNPOLLUTED COOLING WATERS - cooling water to which no chemicals or substances have been added and which have not picked up amounts of pollutants in excess of concentrations allowed in the connection permit.
- 145 WASTEWATER - means sewage.
- 146 WASTEWATER TREATMENT FACILITY - is any system or method used to treat wastewater biologically, chemically, electrically, mechanically or otherwise and includes the wastewater collection system therefore.
- 147 WATER COURSE - means: (a) the bed and shore of a river, stream, lake, creek, lagoon, swamp marsh or other natural body of water; or (b) a canal, ditch, reservoir or other man-made surface feature whether it contains or conveys water continuously or intermittently.

**PART 11 AUTHORITY**

- 201 Except as otherwise provided in this Bylaw, no person shall discharge into any water course any wastewater or waste.
- 202 The provisions of this Bylaw shall apply to all persons using the Town's sewerage system both in and outside the Town, and regardless of whether any person using this system has a contract for sewerage service with the Town.
- 203 The Manager is hereby authorized to administer and enforce the provisions of this Bylaw. In addition to those duties, without limiting them, the Manager may make binding contracts with customers for sewerage service and may levy charges and fines in accordance with this Bylaw.
- 204 The Manager shall have the discretion to discontinue sewerage service in the event of noncompliance herewith.

4  
**TOWN OF FORT MACLEOD**  
**BY-LAW NO. 1805**

- 205 Any owner or occupier of property connected or required to be connected to the sewerage system shall, upon request of the Manager, provide such information as the type, quantity and chemical composition of pollutants which are or may be handled, stored or used on that property, or discharged into the sewerage system.
- 206 (a) Those persons desiring sewerage system service must apply in writing to the Town of Fort Macleod, Town Manager.
- (b) Rates to be charged for sewerage service shall be as per Schedule "A" and set from time to time by Town Council.
- 207 (a) The Inspector shall be permitted reasonable access upon all property in the Town for the purpose of inspection measurement, sampling and testing in accordance with this Bylaw.
- (b) If such inspection discloses any act or omission contrary to the provisions of this Bylaw or the inspection discloses any defect or insufficiency in the location, construction, design or maintenance of any equipment in connection with the wastewater discharge, the Inspector may direct the owner or occupier of the premises to correct the act or omission or any defect or insufficiency.
- (c) No person shall obstruct or interfere with the Inspector in the discharge of his duties under this Bylaw.

**PART III**  
**SEWER SERVICE**

- 301 No person shall uncover, make any connections with or opening into, use, alter or disturb any public sewer or appurtenances thereof without prior written authorization from the Manager
- 302 No person shall connect private sewer lines to sanitary, combined, or storm sewers without a permit.
- 303 No person shall discharge or cause to be discharged into any sewer system or watercourse within, or entering the Town sewerage system, any wastewater, Clearwater waste or storm water without obtaining written approval to do so from the Manager. No such approval shall be given by the Manager until:
- (a) Such person has made application in writing for permission to discharge wastewater, clear water waste or storm water into a sewer within, or entering the Town system;
- (b) Such applicant, if requested, has given the chemical and physical analysis, quantity and rate of discharge of sewage proposed to be so discharged, any other detailed information that is required, including all pertinent information relating to any proposed pretreatment before discharge;
- (c) Such person has given assurance that the discharge into the sewerage system will at all times meet the criteria set out in Clause 501 or Clause 503, whichever is applicable; and
- (d) Such person has provided for facilities to control the rate of discharge into the sewerage system as directed by the Manager.

**PART III**  
**SEWER SERVICE**

- 304 In order for the Town to construct sewer services from the sewer main to the property line, the property owner requesting the service shall supply the Town with the size and accurate location of all sewer services.
- 305 The Town shall maintain the sewer service from the main to the property line and assume responsibility for blockages caused by collapsed service lines, otherwise it shall be the responsibility of the property owner, to correct any blockage. The cost of any work done by the Town may be charged back to the property owner.

**TOWN OF FORT MACLEOD  
BY-LAW NO. 1805**

- 306 The proper care and maintenance of the sewer service connection line from the main to the users point of entry shall be the responsibility of the owner or the occupant. Where the sewer line becomes plugged the owner or occupant must first call a qualified plumber and attempt to clean the line or establish the probable cause at his own expense. The Town will be responsible for the cost of excavation and repair only if it is found that the cause of the stoppage is the result of faulty material or construction on the Town's portion of the service line.
- 307 In the event that any sewer service or private sewer system is abandoned, the owner or occupier, at his expense, shall effectively cap the sewer at a suitable location within his property in order to prevent wastewater and storm water from backing up into the soil and to prevent soil or dirt from being washed into the sewer.
- 308 Where required by the Manager, the owner or occupier of property serviced by a sewer shall install a suitable sampling manhole in the sewer service for determining the wastewater quality, temperature, rate of flow and other measurements. Such manhole shall be:
- (a) Located and constructed in accordance with plans approved by the Inspector, and;
  - (b) Installed and maintained at all times by the owner at his own expense.

**PART IV  
WASTEWATER FACILITIES  
ON PRIVATE PROPERTY**

- 401(a) The owner of property used for employment, recreation or other purposes, situated within the Town and abutting on any street, lane or right of way in which there is a public sanitary or combined sewer shall install, at his own expense, suitable toilet facilities therein and shall connect such facilities with the proper sewer in accordance with the provisions of regulations under the Safety Codes Act, R.S.A. 1991 Chapter S- 0.5, within sixty (60) days of the Health Officer notifying him to do so.
- (b) Where a public sanitary sewer or combined sewer is not available, the owner of property described in (a) shall connect the building sewer to a private wastewater disposal system which shall comply with the provisions of this Bylaw, the Safety Codes Act and the regulations of the Provincial Board of Health.
- 402 At such time as a public sewer becomes available to a property served by a private wastewater disposal system, the provisions of Clause 401 (a) shall then apply to the property and a direct connection shall be made to the public sewer and any septic tanks, cesspools or similar private wastewater disposal facilities shall be abandoned and filled with suitable material.
- 403 Any sewer service on private property shall be constructed by the owner at his expense in conformity with this Bylaw and The Safety Codes Act and regulations passed thereunder.
- 404 Permits for building sewers on private property shall be obtained from the Development Officer. Permit applications shall be supplemented by any plans, specifications or other information considered necessary by the Plumbing Inspector.
- 405 The owner shall, at his own expense, maintain the building sewer from his property line to the building.
- 406 The owner shall, at his own expense, operate and maintain his private wastewater disposal facilities in a sanitary condition.
- 407(a) (1) Grease, oil and sand interceptors shall be provided on private property by the owner for all garages, gasoline service stations and vehicle and equipment washing establishments.
- (2) Interceptors will be required for other types of business if the Manager determines they are necessary for the proper handling of liquid waste.
- (b) All interceptors shall be:
- (1) of a type and capacity approved by the Manager,
  - (2) located to be readily and easily accessible for cleaning and inspection, and
  - (3) maintained by the owner or occupier at his expense.

6  
TOWN OF FORT MACLEOD  
BY-LAW NO. 1805

408 Catch basins shall be maintained on private property by the owner or occupier at his expense.

**PART V  
WASTEWATER STRENGTH LIMITS**

501 STORM SEWERAGE SYSTEM

Unpolluted water shall be discharged to the storm sewerage system or to a natural watercourse where available. Water, including storm water, surface water, Clearwater waste and sub-surface drainage (except foundation drainage) shall be considered to be unpolluted if:

(a) it does not contain conventional, non-conventional, or priority pollutants in measurable concentrations other than those identified below in less than or equal to the concentrations listed:

Conventional Pollutants

B.O.D. - 20 mg/L  
C.O.D. - 40 mg/L  
Grease and Oils - 5.0 mg/L  
Nitrogen (ammonia plus organic) - 1.0 mg/L  
Non-Filterable Residue - 20 mg/L  
Total Phosphorus - 0.05 mg/L  
Copper - 0.02 mg/L  
Fluoride - 1.5 mg/L  
Iron - 0.3 mg/L  
Manganese - 0.05 mg/L  
Sulfide - 0.5 mg/L  
Zinc - 0.05 mg/L  
Total Coliform density 5,000 per 100 ml in 90% of samples  
Fecal Coliform density 1,000 per 100 ml in 90% of samples

Priority Pollutants

Arsenic - 0.1 mg/L  
Barium - 1.00 mg/L  
Boron - 0.5 mg/L  
Cadmium - 0.05 mg/L  
Chromium - 0.05 mg/L  
Cyanide - 0.01 mg/L  
Lead - 0.05 mg/L

Mercury - 0.0001 mg/L  
Phenolic - 0.005 mg/L  
Selenium - 0.01 -mg/L  
Silver - 0.05 mg/L  
Pesticides (total) - 0.01 mg/L

(b) its pH is greater than 6.5 and less than 9.0;

(c) it has a colour less than 30 true colour units;

**PART V  
WASTEWATER STRENGTH LIMITS (cont'd.)**

(d) its temperature is lower than 65C.

These lists shall not be limited to the above materials. They include any materials cited in Provincial and Federal Legislation and amendments thereto including priority pollutants listed in the Federal Environmental Contaminants Act.

502 SANITARY SEWER

No person shall discharge or cause to be discharged any surface water, sub-surface drainage (except foundation drainage) or unpolluted Clearwater waste to any sanitary sewer. The Manager may on application authorize such discharge where exceptional conditions prevent compliance with the foregoing provision.

503 SANITARY SEWERAGE SYSTEM

Except as hereinafter provided, no person shall discharge or cause or permit to be discharged any of the following described water or wastes to any sanitary sewerage system;

7  
TOWN OF FORT MACLEOD  
BY-LAW NO. 1805

- (a) any liquid or vapour having a temperature higher than 75°C;
- (b) any gasoline, solvents or similar products;
- (c) any tar or other viscous material of mineral origin;
- (d) any garbage that has not been shredded so as to pass through a 6mm screen;
- (e) any ashes, cinders, wood, wood-shavings, sawdust, rags, sand, mud, straw, metal, glass, fiberglass, plastics, eggshells, feathers and improperly shredded paper or other solids;
- (f) any water or wastes which contain material that will solidify or become viscous at temperatures between 5°C and 80°C;
- (g) animal parts or wastes including; but not limited to:
  - 1) any manure or intestinal contents from horses, cattle, sheep, swine or poultry,
  - 2) hooves or toenails,
  - 3) intestines or stomach casings or animal body parts,
  - 4) bones
  - 5) bristles and hair,
  - 6) hides or parts thereof,
  - 7) fat or flesh particles larger than will pass through a 6mm screen,
  - 8) fleshings and hair resulting from tanning operations,
- (h) any wastewater having a pH lower than 6.0 or above 10.0;
- (i) wastewater which is in or is capable of being transformed into, two or more separate layers;
- (j) Wastewater containing substances in concentrations exceeding the following:
  - Antimony - 1.0 mg/L
  - Arsenic - 1.0 mg/L
  - Barium - 3.0 mg/L
  - Boron - 1.0 mg/L
  - Cadmium - 0.05 mg/L
  - Chromium - 1.0 mg/L
  - Chlorinated hydrocarbons 0.02 mg/L
  - Copper - 0.5 mg/L
  - Cyanide - 1.0 mg/L
  - Lead - 1.0 mg/L
  - Manganese - 1.0 mg/L
  - Mercury - 0.1 mg/l
  - Nickel - 0.5 mg/L
  - Total Pesticides - 0.1 mg/L
  - Phenolic Compounds - 0.1 mg/L
  - Selenium - 1.0 mg/L
  - Silver - 1.0 mg/L
  - Sulfide - 1.0 mg/L
  - Zinc - 1.0 mg/L
- (k) Pollutants other than those listed in (j) prohibited from being discharged under Federal or Provincial legislation and amendments thereto;
- (l) Any noxious or malodorous gas or substance capable of creating public nuisance including, but not limited to, hydrogen sulphide, mercaptans (thiols), carbon disulphides, other reduced sulphur compounds, amines, and ammonia;
- (m) Wastewater containing substances in concentrations exceeding the following:
  - (1) 300 mg/L nonfilterable residue (suspended solids), and/or
  - (2) 300 mg/L B.O.D. and/or
  - (3) 300 mg/L chemical oxygen demand (C.O.D.) and/or
  - (4) 100 mg/L grease and oils and/or
  - (5) 100 mg/L hydrocarbons of petroleum origin and/or
  - (6) 100 mg/L total Kjeldahl nitrogen (TKN) and/or
  - (7) 25 mg/L total phosphorus
- (n) lime slurry and residues;

8  
**TOWN OF FORT MACLEOD**  
**BY-LAW NO. 1805**

(o) any substance which, in the opinion of the Manager, is or may become harmful to any recipient water course or sewer system or part thereof, may interfere with the proper operation of the sewer system, may impair or interfere with any treatment process, or may become a hazard to persons, property or animals.

504 If a person discharges, or allows to be discharged, clear water waste or wastewater to a sewer within or entering the Town exceeding any of the following characteristics and limits:

- (a) B.O.D. - 300 mg/L
- (b) C.O.D. - 300 mg/L
- (c) non-filterable residue - 300 mg/L
- (d) grease and oils - 100 mg/L
- (e) hydrocarbon of petroleum origin - 50 mg/L,
- (f) TKN - 80 mg/L
- (g) total phosphorus - 20 mg/L

then such persons shall pay a surcharge computed as set out from time to time by resolution of Town Council, and the cost of clean up and damages caused by the discharged substances.

505 The following regulations apply to wastewater hauled for disposal to the Town's sewer system:

- (a) pursuant to the Business License Bylaw of the Town, and any changes and amendments thereto, persons hauling wastewater such as septic tank sludge and other water for discharge into the Town's sewer system shall obtain a license.
- (b) the license is subject to cancellation for any violation of this Bylaw.
- (c) Persons hauling wastewater or other waters for treatment shall discharge the wastewater or other waters into the Town's sewer system only at sites designated for such disposal.
- (d) wastewater and other waters discharged shall meet the limits established in clause 503.
- (e) treatment of wastewater or other waters so discharged shall be paid for in accordance with fees set from time to time by resolution of Town Council.
- (f) any person discharging water or wastewater to the sewer system at the designated sites shall allow the material being discharged to be sampled and shall provide information on the wastewater being discharged. This information shall include, but not be limited to, source of wastewater, quantity of wastewater, trucking firm name, and truck license number.

506 No person shall place or deposit, or permit to be deposited in any manner that is unsanitary in the opinion of the Health Officer upon public or private property within the Town of Fort Macleod or in any area under the jurisdiction of the Town, any human or animal excrement, garbage or other objectionable waste.

507 No person shall discharge to any natural outlet within the Town or any area under the jurisdiction of the Town, any sanitary wastewater, industrial wastewater or other polluted water except where pretreatment has been approved in accordance with the provisions of this bylaw and the concentration of pollutants has been reduced to or below the levels indicated in Clause 501.

**PART VI**  
**SAMPLING AND PRETREATMENT**

601 (a) Where the municipality or person using the sewerage system must provide pretreatment of wastewater, clearwater waste or stormwater to bring it within the limits established in this bylaw, that pretreatment facility shall be provided at the expense of the user.

(b) where pretreatment facilities are required, they shall be maintained continuously in satisfactory and effective operation by the owner at his expense.

602 All measurements, tests, and analyses of the characteristics of industrial waste, wastewater or water to which reference is made in this Bylaw shall be determined in accordance with:

- (a) Standard Methods;



**TOWN OF FORT MACLEOD  
BY-LAW NO. 1805**

- (b) Methods Manual for Chemical Analysis of Water and Wastes, Alberta Environment Environmental Protection Services, Pollution Control Division,, Pollution Control Laboratory;
  - (c) Annual book of A.S.T.M. Standards - American Society for Testing and Materials; or
  - (d) Other methods consistent with, or promulgated in, the professional literature. The measurements, tests and analyses shall be determined from aliquots of samples collected from the sampling manhole or other sampling points approved by the Manager.
- 603 No statement contained in this Bylaw shall be construed as preventing any special agreement or arrangement between the Town and any industrial concern whereby an industrial waste of unusual strength or character may be accepted by the Town for treatment subject to payment thereof by the industrial concern.
- 604 Sampling shall be conducted and decisions regarding sampling will be made by the Inspector. The procedure for taking individual and composite samples for the purpose of determining surcharges and conducting tests is outlined below.
- (a) monitoring to determine pollutant concentrations may be performed on one or more grab samples obtained at any time from an approved sampling points.
  - (b) monitoring to determine wastewater overstrength surcharge assessment shall be performed on daily composite samples obtained from approved sampling points and combined using a method identified below. The following is the standard procedure for this sampling:
    - (1) grab samples of approximately equal volumes will be taken at random time intervals during the customer's operating day or over a 24 hour period.
    - (2) the Town's water meter or the industry's effluent flow meter will be read when they are readily accessible and the reading recorded each time a grab sample is collected.
    - (3) where the meter is not readily accessible, the sampler may observe the flow in the sewer line being sampled and estimate the rate of flow.
    - (4) the series of grab samples collected will be combined into a composite sample for analysis. The grab samples may be combined in proportion to the volume of water used or discharged during the sampling period, in proportion to the estimated flow, or where neither actual nor the estimated flow is available, the grab samples may be combined on an equal volume basis. Any combination of the above may be used in the appropriate circumstances.

**PART VII RATES**

- 701 The Town levies wastewater service charges on all lands served by or connected to the sewerage system of the Town, which are to be paid monthly and can be found in Schedule "A", the rates are set from time to time by Town Council.
- 702 Collection of the revenue derived from the sewage system, the payment of disbursements connected therewith, and the supervision of all accounts and records shall be under the immediate control and direction of the Manager. The Public Works Foreman shall promptly notify the Manager of all connections made so that the proper charges may be made against all properties connected to the system.

**PART VIII  
PENALTIES**

- 801 If the owner or occupier of a building, for which a sewer connection has been required pursuant to Clause 401 of this Bylaw, neglects or refuses to comply with the notice within sixty (60) days of receipt thereof, the Town may make or repair or cause to be made or repaired the said connection at the expense of the said owner or occupier.
- 802(a) When the occupant is the owner of a building or lot or part of a lot, the sum payable by him for the sewer service supplied by the Town to him or for his use and all rates, costs and charges imposed by this Bylaw are a preferential lien and charge on the building or lot or part of a lot and on the personal property of the debtor and may be levied and collected in a like manner as municipal rates and taxes are recoverable.
- (b) when the occupant to whom the sewer service has been supplied is a person other than the owner of a building or lot, the sum payable by the occupant is a debt due by him and is a preferential lien and charge on his personal property and may be levied and collected with costs by distress.

**TOWN OF FORT MACLEOD  
BY-LAW NO. 1805**

- 803 (a) any person who contravenes any provision of this bylaw is guilty of an offence and is liable upon summary conviction to a fine not exceeding \$2,500 exclusive of costs for each contravention of this bylaw.
- (b) any person who contravenes Clause 501, Clause 502 or Clause 503 -of this Bylaw is guilty of an offense and upon summary conviction is liable to a minimum fine of \$500 for each contravention of this bylaw.
- 804 (a) The Manager may authorize discontinuation of sewer service and may plug or seal off the sewer line discharging unacceptable sewage, when provisions of this Bylaw are not complied with.
- (b) The sewage may be prevented from being discharged into the sewerage system until evidence satisfactory to the Manager has been produced that no further breaches of the provisions of this Bylaw will occur or are likely to occur.
- 805 All persons who by themselves, their servants or agents, by act, default, neglect or omission, occasion any loss, damage or injury to the sewerage system are liable to the Town for or in respect thereof.
- 806 (a) The expense incidental to the laying, connecting, disconnecting or repairing as herein provided of service pipes of sewers when the work is done by the Town on private property, is payable by the owner on demand by the Town.
- (b) if the cost referred in subsection (a) of this section is not paid within ninety (90) days of notification thereof, the cost shall be levied and collected as a municipal tax.
- 807 (a) Any person not complying with this Bylaw shall be responsible for all fines, penalties, and costs resulting from that act.
- (b) the costs imposed on the owner or occupier referred to in subsection (a) also include fines imposed upon the Town by the Federal or Provincial Government as a result of the said owner or occupier non-compliance with this Bylaw.

**PART VIII  
PENALTIES**

- 808 Where the owner of land with a sewer connected to the sewerage system allowed more than one person, either by lease or by other arrangement, to use the land or a portion thereof, and there is discharge to the sewerage system substances prohibited by this Bylaw, the owner, whether or not one or more of the persons occupying the land is prosecuted in respect thereof, is guilty of an offence and is liable to be prosecuted therefor.
- 809 If, in the Manager's opinion, there is evidence that oversized solids are entering the Town sewer system from any sewer connection, then the Town may install a screen between the connection and the Town sewer system at the owner's expense. The above screen will have a minimum size of 20 mm square openings and shall be removable, but locked in place with the key in the possession of the Manager.
- 810 It shall be the responsibility of the person contributing waste through that connection to remove any solids collected on the screen and dispose of these solids in an approved manner. The Town will not be responsible in any way for any disruption of service which may occur due to blockage of the screen by solids.
- 811 Nothing in this Bylaw relieves any persons from complying with any provision of Federal or Provincial legislation or any other bylaw of the Town.
- 812 By-Law No. 1763 and any and all amendments thereto are hereby repealed in their entirety.

**TOWN OF FORT MACLEOD  
BY-LAW NO. 1805**


**EFFECTIVE DATE**

813 This Bylaw shall come into force on the day it is given third and final reading.

READ A FIRST TIME THIS 14<sup>TH</sup> DAY OF JULY 2014A.D.

READ A SECOND TIME THIS 14<sup>TH</sup> DAY OF JULY 2014A.D.

READ A THIRD TIME AND FINALLY DECLARED PASSED BY COUNCIL THIS 14<sup>TH</sup> DAY OF  
JULY    2014 A.D.

  
\_\_\_\_\_  
DEPUTY MAYOR, Trish Hoskin

  
\_\_\_\_\_  
MUNICIPAL MANAGER, David Connauton

**TOWN OF FORT MACLEOD  
BY-LAW NO. 1805**

**Schedule A  
Rates and fees**

Residential	\$33.00
Apartment (per Unit)	\$22.90
Small Commercial/Offices	\$33.00
Garages & Clinics	\$78.48
Restaurants	\$98.54
Industrial Plants	\$131.52
Hospitals Schools/Laundries	\$164.20
Hotels/Motels	\$67.51
Additional Hotels/Motels per Unit	\$6.67
Commercial Building Multi Unit (per Unit)	\$22.90
Residential Apartments billed Commercial (per Unit)	\$22.90
Residential Multi Unit (per Unit)	\$22.90
Car Wash per Bay	\$65.87
Vacuum truck Dumping	\$131.52
Town Facilities	\$33.00

All rates are per month.